

Mill Bay Water District

Maxxam Job Number: B916619

Report Date: 2019/03/19

VIHA PKG, WELLS/SPRINGS - VICTORIA (DRINKING WATER)

Maxxam ID					VI1962	
Sampling Date					2019/03/07 10:00	
COC Number					WI019157	
		Canadian Drinking Guidelines				
	UNITS	Maximum Acceptable Concentration	Aesthetic Objectives	Operational Guidance Values	MILL SPRINGS RESERVOIR	RDL
Misc. Inorganics						
UV absorbance (254nm)	AU/cm	-	-	-	0.010	0.010
ANIONS						
Nitrite (N)	mg/L	1	-	-	<0.0050	0.0050
Calculated Parameters						
Total Hardness (CaCO3)	mg/L	-	-	-	155	0.50
Nitrate (N)	mg/L	10	-	-	0.108	0.020
Total Organic Nitrogen (N)	mg/L	-	-	-	0.038	0.020
Sulphide (as H2S)	mg/L	-	0.05	-	<0.0020	0.0020
Transmittance at 254nm	%T/cm	-	-	-	97.7	N/A
Misc. Inorganics						
Fluoride (F)	mg/L	1.5	-	-	0.082	0.020
Alkalinity (Total as CaCO3)	mg/L	-	-	-	109	1.0
Total Organic Carbon (C)	mg/L	-	-	-	0.56	0.50
Alkalinity (PP as CaCO3)	mg/L	-	-	-	<1.0	1.0
Bicarbonate (HCO3)	mg/L	-	-	-	133	1.0
Carbonate (CO3)	mg/L	-	-	-	<1.0	1.0
Hydroxide (OH)	mg/L	-	-	-	<1.0	1.0
Anions						
Dissolved Sulphate (SO4)	mg/L	-	500	-	95.5	1.0
Total Sulphide	mg/L	-	0.05	-	<0.0019	0.0019
Dissolved Chloride (Cl)	mg/L	-	250	-	5.2	1.0
MISCELLANEOUS						
True Colour	Col. Unit	-	15	-	<5	5
Nutrients						
Total Ammonia (N)	mg/L	-	-	-	<0.015	0.015
Nitrate plus Nitrite (N)	mg/L	-	-	-	0.108	0.020
Total Nitrogen (N)	mg/L	-	-	-	0.147	0.020
Physical Properties						
Conductivity	uS/cm	-	-	-	400	2.0
pH	pH	-	-	7.0:10.5	7.99	

Physical Properties						
Total Dissolved Solids	mg/L	-	500	-	258	20
Turbidity	NTU	see remark	see remark	see remark	0.14	0.10
Elements						
Total Mercury (Hg)	ug/L	1	-	-	<0.0020	0.0020
Total Metals by ICPMS						
Total Aluminum (Al)	ug/L	-	-	100	<3.0	3.0
Total Antimony (Sb)	ug/L	6	-	-	<0.50	0.50
Total Arsenic (As)	ug/L	10	-	-	1.32	0.10
Total Barium (Ba)	ug/L	1000	-	-	12.1	1.0
Total Beryllium (Be)	ug/L	-	-	-	<0.10	0.10
Total Bismuth (Bi)	ug/L	-	-	-	<1.0	1.0
Total Boron (B)	ug/L	5000	-	-	<50	50
Total Cadmium (Cd)	ug/L	5	-	-	<0.010	0.010
Total Chromium (Cr)	ug/L	50	-	-	<1.0	1.0
Total Cobalt (Co)	ug/L	-	-	-	<0.20	0.20
Total Copper (Cu)	ug/L	-	1000	-	2.06	0.20
Total Iron (Fe)	ug/L	-	300	-	23.4	5.0
Total Lead (Pb)	ug/L	5	-	-	0.78	0.20
Total Manganese (Mn)	ug/L	-	50	-	65.9	1.0
Total Molybdenum (Mo)	ug/L	-	-	-	14.8	1.0
Total Nickel (Ni)	ug/L	-	-	-	<1.0	1.0
Total Selenium (Se)	ug/L	50	-	-	<0.10	0.10
Total Silicon (Si)	ug/L	-	-	-	7050	100
Total Silver (Ag)	ug/L	-	-	-	<0.020	0.020
Total Strontium (Sr)	ug/L	-	-	-	411	1.0
Total Thallium (Tl)	ug/L	-	-	-	<0.010	0.010
Total Tin (Sn)	ug/L	-	-	-	<5.0	5.0
Total Titanium (Ti)	ug/L	-	-	-	<5.0	5.0
Total Uranium (U)	ug/L	20	-	-	6.67	0.10
Total Vanadium (V)	ug/L	-	-	-	<5.0	5.0
Total Zinc (Zn)	ug/L	-	5000	-	14.9	5.0
Total Zirconium (Zr)	ug/L	-	-	-	<0.10	0.10
Total Calcium (Ca)	mg/L	-	-	-	47.0	0.050
Total Magnesium (Mg)	mg/L	-	-	-	9.12	0.050
Total Potassium (K)	mg/L	-	-	-	0.326	0.050
Total Sodium (Na)	mg/L	-	200	-	13.1	0.050
Total Sulphur (S)	mg/L	-	-	-	28.3	3.0
Microbiological Param.						
Heterotrophic Plate Count	CFU/mL	-	-	-	2	1
Iron Bacteria	CFU/mL	-	-	-	2200	25
Sulphate reducing bacteria	CFU/mL	-	-	-	<75	75
Total Coliforms	CFU/100mL	0	-	-	0	N/A
E. coli	CFU/100mL	0	-	-	0	N/A
Calculated Parameters						
Langelier Index (@ 4.4C)	N/A	-	-	-	-0.242	N/A
Langelier Index (@ 60C)	N/A	-	-	-	0.799	N/A

Saturation pH (@ 4.4C)	N/A	-	-	-	8.23	N/A
Saturation pH (@ 60C)	N/A	-	-	-	7.19	N/A

No Fill No Exceedance
Grey Exceeds 1 criteria policy/level
Black Exceeds both criteria/levels
RDL = Reportable Detection Limit
N/A = Not Applicable

Results relate only to the items tested.